

# **STABILITY CERTIFICATE**

**NAME**

**SOWMA PUBLIC SCHOOL**

**Address:**

**VIRALIMALAI ROAD, SEVALLUR VILLAGE, MANAPPARAI,  
MANAPPARAI TALUK, TRICHY DISTRICT.**

**PERIOD**

**01.04.2025 TO 31.03.2028 (3 YEARS)**

**Er.A. SHEIK MOHAMED**

**B.E., M.I.E., F.I.V., M.I.N.S.T., M.Sc., (RE&V)**

**PANEL ENGINEER CLASS-1-A**

**APPROVED BY DISTRICT COLLECTOR**

**APPROVED BY THE PWD, TAMILNADU**

**No.5, 2<sup>nd</sup> FLOOR, TAB COMPLEX,  
OPP. AMERICAN HOSPITAL,  
41 BHARATHIDASAN SALAI, CONTONEMENT,  
TRICHY – 620 001,  
Mob. No.9025983341, PHONE No.0431-2410283**

## FORM "A"

(Form of application under sub section (1)/Sub section (2) of Section of 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 3 of the Tamilnadu Public Buildings(Licensing) Rules 1966.

From

Sowma Public School,  
O.SF.No.741/3A,742/1, 2,3,4 & 5,  
TS.No.7, 9pt & 77 pt, Block No.1, Ward.G,  
Viralimalai Road, Sevallur Village,  
Manapparai, Manapparai Taluk,  
Trichy District.

To

The Tahsildar,  
Taluk Office,  
Manapparai.

1. Intended/to use the building / to continue to use the existing public buildings / to use the existing building not at present used as a public building / which is situated in the site or plot of land, Town or Revenue Survey No. O.SF.No.741/3A,742/1, 2,3,4 & 5, TS.No.7, 9pt & 77 pt, Block No.1, Ward.G, Street or Road Viralimalai Road, Sevallur Village in Manapparai Taluk the ward of division / village / Taluk / District Trichy District and specified in the statement enclosed, as a public building for a period of 3 years and months from 01.04.2025 to 31.03.2028.

2. The year of construction and the present approximate cost of construction and purpose for which it is to be used or is being used as Public Building are also furnished in the statement accompanying this application

3. I enclose a Chalan for Rs.

4. I also enclose a certificate of Structural Soundness in the prescribed form furnished by the Engineer Thiru.**Er.A.SHEIKMOHAMED**, Chartered Engineer.

(or)

I have not enclosed the certificate of structural soundness from the Engineer.

Dated the

(Signature of the owner of the building)

Enclose : 1. Statement

2. Chalan for Rs.

Towards the application fee

Explanation:-Separate application shall be made in respect of each building.

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,

M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)

**PANEL ENGINEER CLASS 1 – A,**

**Approved by District Collectorate,**

**Approved by the PWD, Tamilnadu.**

Mobile No.9025983341

Phone No. 0431-2410283

## STATEMENT ACCOMPANYING FORM "A"

1. Door Number of building : Sowma Public School,
2. Location (street Number, ward /Number : O.SF.No.741/3A, 742/1,2,3,4 & 5,  
Name of Place ie. Corporation/Municipality/ TS.No.7, 9 pt, & 77 pt, Block No.1,  
Cantonment. Ward.G, Viralimalai Road,  
Sevallur Village, Manapparai,  
Manapparai Taluk, Trichy District.
3. Year of construction : 2012
4. Approximate cost of construction : Rs.135 - 00 Lakhs
5. Purpose for which the building is being used  
or Proposed to be used. : Educational Purpose
6. Purpose for which the building has hitherto  
been used : Educational Purpose
7. Details of construction of the building  
(particulars foundation, soil specification  
of the various parts under) : Hard Gravel Soil
  1. Foundation : RCC Column Foundation
  2. Basement : Brick work with Cement Mortor
  3. Superstructure : Cement Block with Cement Mortor
  4. Floor and roof are to be given : Ground Floor, First Floor & Second  
Floor with R.C.C. Roof & Second Floor  
Colour Coated Sheet Roof
8. Period for which license is required : 3 years (01.04.2025 to 31.03.2028)
9. Number of Persons to be accommodated : 1500 No. of Persons

Station: Trichy

Date : 08.02.2025

**Er.A. SHEIK MOHAMED**  
**BE MIE FIV MINST MIPE**  
**(SIGNATURE OF THE ENGINEER)**  
**PANEL ENGINEER CLASS - 1-A**

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was grated for the use of the building or a portion of the building originally is changed or altered subsequently.

Station:

Date :

**(SIGNATURE OF THE OWNER OF  
THE BUILDING)**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu.

Mobile No.9025983341

Phone No. 0431-2410283

## FORM "B"

(Form of Certificate of Structural Soundness under sub section (4) of section 4 of the Tamilnadu public buildings (licensing) Act, 1965 (Tamilnadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

### (1) Foundation

- (i) Depth below ground level : 1.8 M
- (ii) Nature of soil met with at foundation Level : Hard Gravel Soil
- (iii) Pressure at foundation : 18.5 Ton / Sq.m.
- (iv) Probable safe bearing capacity of the strata met With at foundation : 28 Ton / Sq.m.

### (2) Superstructure

- (i) Maximum stress in the most critical Section of Masonry and concrete. Concrete - 5 N / mm<sup>2</sup>  
: Masonry - 2.5 N / mm<sup>2</sup>
- (ii) Nature of masonry and concrete and its Safe Permissible stress. Concrete - 7 N / mm<sup>2</sup>  
: Masonry - 3.5 N / mm<sup>2</sup>

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.04.2025 to the 31.03.2028 Inclusive.

Date:08.02.2025

Signature of the Engineer,

  
Er. A. SHEIK MOHAMED  
Registration No.  
Class  
B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
Address  
PANEL ENGINEER CLASS - 1-A  
(P.T.O)

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

Location of the building (Door No. St.No. Place of Name)	Age of the buildings	Value of Building at current rates	No. of Stories	Short description of structure steel, RCC framed or Load bearing in Masonry
1.	2.	3.	4.	5.
Sowma Public School, Viralimalai Road, Sevallur Village, Manapparai, Manapparai Taluk, Trichy District.	13 Years Old	Rs.135 - 00 Lakhs	Ground Floor First Floor Second Floor	R.C.C. Framed Structure with R.C.C. Beam and slabs. Brick walls in Cement Mortor.
Purpose for which the building is certified for use	Period for which the building will be structurally sound	No. of persons to be accomodated	Remarks	
6.	7.	8.	9.	
Educational Purpose	3 years	1500 No. of Persons	<p>Building is sound and strong (Other items, buildings are not included in the certificate except this building)</p> <p>Note: Periodical repairs and renovations are to be carried out properly whenever and wherever necessary.</p> <p>Sunshade, Portico &amp; Electrification should be maintained Properly by the building owner. If any problem comes in the above mater in future in the building owner is the full responsibility.</p>	

Station: 08.02.2025

Signature of the Engineer

Registration No.

**Er.A. SHEIK MOHAMED**

**B.E., M.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,**

**PANEL ENGINEER CLASS - 1-A**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu,

Mobile No.9025983341  
Phone No. 0431-2410283

### FORM "C"

(Form of Certificate of Structural Soundness under sub-section (4) of section 4 of the Tamilnadu public buildings (licensing) Act, 1965 (Tamilnadu Act of 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules, 1966.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

#### (1) Foundation


- |       |   |                    |
|-------|---|--------------------|
| (i)   | Depth below ground level  | : 1.8 M            |
| (ii)  | Nature of soil met with at foundation level                         | : Hard Gravel Soil |
| (iii) | Pressure at foundation  | : 18.5 Ton / Sq.m. |
| (iv)  | Probable safe bearing capacity of the strata met With at foundation | : 28 Ton / Sq.m.   |

#### (2) Superstructure

- |      |  |   |
|------|--|---|
| (i)  | Maximum stress in the most critical section of Masonry and concrete. | Concrete - 5 N / mm <sup>2</sup><br>: Masonry - 2.5 N / mm <sup>2</sup> |
| (ii) | Nature of masonry and concrete and its safe Permissible stress.      | Concrete - 7 N / mm <sup>2</sup><br>: Masonry - 3.5 N / mm <sup>2</sup> |

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.04.2025 to the 31.03.2028 Inclusive.

Date:08.02.2025

  
Signature of the Engineer,  
Er. A. SHEIK MOHAMED  
B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
PANEL ENGINEER CLASS - 1-A (P.T.O)

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

Location of the building (Door No. St.No. Place of Name)	Age of the buildings	Value of Building at current rates	No. of Stories	Short description of structure steel, RCC framed or Load bearing in Masonry
1.	2.	3.	4.	5.
Sowma Public School, Viralimalai Road, Sevallur Village, Manapparai, Manapparai Taluk, Trichy District.	13 Years Old	Rs.135 - 00 Lakhs	Ground Floor First Floor Second Floor	R.C.C. Framed Structure with R.C.C. Beam and slabs. Brick walls in Cement Mortar.
Purpose for which the building is certified for use	Period for which the building will be structurally sound	No. of persons to be accommodated	Remarks	
6.	7.	8.	9.	
Educational Purpose	3 years	1500 No. of Persons	<p>Building is sound and strong (Other items, buildings are not included in the certificate except this building)</p> <p>Note: Periodical repairs and renovations are to be carried out properly whenever and wherever necessary.</p> <p>Sunshade, Portico &amp; Electrification should be maintained Properly by the building owner. If any problem comes in the above mater in future in the building owner is the full responsibility.</p>	

Station: 08.02.2025

Signature of the Engineer

Designation

**Er.A. SHEIK MOHAMED**  
**B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,**  
**PANEL ENGINEER CLASS - 1-A**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu.

Mobile No.9025983341  
Phone No. 0431-2410283

FORM "E"

(Form of report to be made to the competent authority by Inspecting Authorities or officers appointed under other Acts under section 28 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamilnadu Act 13 of 1965) referred to in Rule 7 of the Tamilnadu Public Buildings (Licensing Rules, 1966).

1. Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law. : Er.A. SHEIK MOHAMED,  
B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,  
M.I.P.H.E.,M.I.T.A.,D.H.M.,M.A.,(Ling)  
Panel Engineer Class 1 - A  
Chartered Engineer
2. Location of the building inspected (Door No. Street No. name of place, i.e., Municipality Town ship, Cantonment) : Sowma Public School,  
O.SF.No.741/3A, 742/1,2,3,4 & 5,  
TS.No.7, 9pt & 77 pt,  
Viralimalai Road, Sevallur Village,  
Manapparai, Manapparai Taluk,  
Trichy District.
3. Date of Inspection : 08.02.2025
4. Purpose for which the building is used : Educational Purpose
5. Nature of defects noticed : -----
6. Suggestion for rectifying defects : -----
7. If in a dangerous condition immediate steps recommended to be takes : -----

Place : Trichy  
Date : 08.02.2025

(SIGNATURE OF THE INSPECTION AUTHORITY)

**Er.A. SHEIK MOHAMED**  
B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,  
PANEL ENGINEER CLASS - 1-A

**Er. A.SHEIK MOHAMED,**


B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu.

Mobile No.9025983341  
Phone No. 0431-2410283

**DECLARATION**

I, Er.A. Sheik Mohamed, B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E., M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling), Chartered Engineer , Govt. Approved Valuer, Panel Engineer Class 1 – A, Son of Late P. Abubacker residing at No. 5, Iind Floor, TAB Complex, Opp. American Hospital, Cantonment, Trichy, do hereby declare that I possess the qualification and experience in the Table 2 Rule 11 of the Tamilnadu Public Building (Licensing) Act 1965 of rule 1966 issuing the Certificate of Structural Soundness of the building covered by the Certificate. Subject to the regular instants.

01. Name and Address : Er.A. SHEIK MOHAMED,  
B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling),  
Chartered Engineer,  
Panel Engineer Class 1 – A (Proceeding of  
District Collector copy enclosed)  
No.5, Iind Floor, TAB Complex, Opp.American  
Hospital, Cantonement, Trichy – 620 001.
02. Qualification : B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling),  
Panel Engineer Class 1 – A (Proceeding of the  
District Collector copy enclosed – issuing  
building Stability Certificate for the Cost of the  
Building up to 50 lakhs and above 50 lakhs  
also)
03. No. of the years experience : More then 30 years in the various building  
activities.

  
Er. A. SHEIK MOHAMED, B.E.,  
Panel Engineer Class 1 – A, (proceeding  
issued by the District collector for issuing  
building Stability certificate for the cost of  
the building upto 50 lakhs and more then

50 lakhs also)  
**Er.A. SHEIK MOHAMED**  
**B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,**  
**PANEL ENGINEER CLASS - 1-A**

PROCEEDINGS OF THE DISTRICT COLLECTOR, TIRUCHIRAPPALLI

PRESENT : Thiru. V. PANDIAN, I.A.S.,

R.Dis(D1)83202/2004

Dated : 08.01.2005

Sub : Tamil Nadu Public Building (Licensing) Act 1965 and Rules 1966 - Tiruchirappalli District - Drawel of Registered Panel Engineers under Rule 11 - Application of Thiru.A.Sheik Mohammed for inclusion of his name in the list of Private Panel Engineers under class IA - category in Tiruchirappalli District - Orders issued.

- Read :
- 1.Thiru.A.Sheik Mohammed, Panel Engineer, (Class-II)  
Application dt:21.04.2003.
  2. Lr.No.313M/D1/F.532, Dated:16.12.2004 received from the Superintending Engineer, P.W.D., Buildings construction and Maintenance circle, Tiruchirappalli.
  3. Other connected records.

^^^^^^


ORDER:

The name of Thiru. A.Sheik Mohammed, Chartered Engineer residing at No.5,41.Bharathidasan Salai Cantonment, Tiruchirappalli has been included in the panel of Private Registered Engineers of Tiruchirappalli District maintained in this office with the approval of the Board of Engineers as laid down under Rule 11 of the Tamil Nadu Public Buildings (Licensing) Rules 1966 for the purpose of issuing Structural Soundness Certificates for the Public Buildings under the purview of Tamil Nadu Public Buildings (Licensing) Act 1965 as per this office No.D.Dis.91796/94(D1)Dated:24.12.94.


2) Now his name is registered under the category of Class I-A Engineer for furnishing Structural Soundness Certificates for buildings above Rs.30.00 lakhs in Tiruchirappalli District.

Sd-V.Pandian  
District Collector,  
Tiruchirappalli

-By Order-

  
Huzur Sarishtadar (Magisterial)  
10/1/05

To: as on reverse

  
10/1/05

(P.T.O)